

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
L.M. Dey Garden, D.H. Road, Silpara, Pin - 700008**

Memo No : IND/WB/FES/20192020/83936

DATE: 18/02/2020

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**MATHURAPUR MASS TEACHERS TRAINING INSTITUTE
AND MASS EDUCATION TEACHERS TRAINING INSTITUTE
TENTULBERIA,P.O- MATHURAPUR,
P.S- MATHURAPUR, DIST.- 24 PGS(S), PIN- 743 354.
Baruipur F.S., Mathurapur,
South 24 Parganas - 743354 .**

Sub :Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational at the premises no.- TENTULBERIA,P.O- MATHURAPUR, P.S- MATHURAPUR, DIST.- 24 PGS(S), PIN- 743 354., Mathurapur, South 24 Parganas - 743354

This is in reference to your Application No. IND/WB/FES/20192020/83936,dated 18/02/2020, regarding the Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational at the premises no.- TENTULBERIA,P.O- MATHURAPUR, P.S- MATHURAPUR, DIST.- 24 PGS(S), PIN- 743 354., Mathurapur, South 24 Parganas - 743354.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. 1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the driveway.
2. The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.
3. To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.
5. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
6. The employees and security staff shall be conversant with installed Fire fighting equipment's of the building and to operate in the event of Fire and testing.
7. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
8. Electrical switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher confirming I.S. specification.
9. The Fire check door shall be sealed with rubber sealing properly in the order to prevent percolation of smoke.
10. First aid Fire fighting system shall be provided as per I.S. specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building to keep them in perfectly good working condition at all the times.
12. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.
13. Periodical flashing of water from the fire water pipe line shall be made to maintain efficient working performance of above mentioned system.
14. This F.S.C. is valid for 03(Three) years from the date of issue of this letter.
15. F.S.C is to be obtained from the Divisional Fire Officer, West Bengal Fire & Emergency Services, for performances of all the Life and Fire Safety arrangements and installation of the building.

Signature valid

Digitally signed by DIPAK
KUMAR GHOSH
Date: 2020.02.18 15:02:01 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services